

Supplier Declaration of Conformity

Supplier Details

Name (of NZ manufacturer, importer or agent)

Schneider Electric (NZ) Ltd

Address

11 Moncur Place
Middleton
Christchurch
New Zealand

Telephone

Fax

New Zealand Company Number

+64 3 338 9059	+64 3 339 1657	363533
----------------	----------------	--------

Product Details

Parent Product name, type, model and serial numbers:

56SWK332 – 56 Series Key-Lock Weather Protected Switch






Product variations to the parent model number:

Abbreviation	Description
GY	High Impact Grey
RO	Chemical Resistant Orange
RW	Chemical Resistant White

Ratings:

415 V ~, 50Hz, IP66, 32A, M180, 1 way, 3 pole

Additional product information:

Supplier Identification	<div style="display: flex; justify-content: space-around; align-items: center;">    </div> <p style="text-align: center; margin-top: 5px;">Trade name, Branding or Company name</p>
RoHS Compliance	<div style="display: flex; align-items: center;">  <p>This product is compliant to European Directive Restriction of Hazardous Substances 2002/95/EC</p> </div>
Regulatory Compliance Mark (RCM)	<div style="display: flex; align-items: center;">  <p>This product complies with all relevant Australian and New Zealand electrical safety standards, including EMC.</p> </div>
Energy Safety Approval No.	<div style="display: flex; align-items: center;"> <div style="border: 1px solid black; padding: 5px; margin-right: 10px; text-align: center; width: 40px;"> V41 </div> <p>This product has been issued a Certificate of Approval or Compliance from EnergySafe Victoria, indicating it has been assessed and is suitable and approved for sale in both Australia and New Zealand.</p> </div>

Documents used as the basis for compliance:

Standards Compliance:	
AS/NZS 3100:2002	Approval and test specification - General requirements for electrical equipment
AS/NZS 3133:2003	Approval and test specification - Air break switches
AS/NZS 3133:2008	Approval and test specification - Air break switches
AS/NZS 3121:2002	Approval and test specification - Insulating mouldings
AS 60529:2001	Degrees of protection provided by enclosures (IP code)

AS 60529:2004 IEC 60947-3:2008 Ed. 3	Degrees of protection provided by enclosures (IP code) Low-voltage switchgear and control gear - Part 3 - Switches, disconnect
Test Reports & supporting documentation:	R09CA06198B-00 R09CA43957-VA00 R09CA32573-SA01 R7762-00

Declaration

We Schneider Electric (NZ) Limited declare under our sole responsibility that the product is in conformity with the relevant clauses of the listed standard(s) or other normative document(s).

For further information please contact Customer Care:
New Zealand: 0800 652 999
Australia: 1300 735 329

Signature of Authorised Person



Printed Name

Richard Coia

Position in Organisation

Design Supervisor
Christchurch
New Zealand

Date of Declaration

2nd November 2009